

# CERTIFICATE

KEMA No.: 2002756.01

Issued to:  
Applicant:  
**OBO Bettermann GmbH & Co.**  
**Huingser-Ring 52**  
**MENDEN, Germany**

Manufacturer/Licensee:  
**OBO Bettermann GmbH & Co.**  
**Huingser-Ring 52**  
**MENDEN, Germany**

Product : surge-protection device

Trade name : OBO  
Type/model : MC 50-B

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 61643-1:1998
- an inspection of the production location according tot CCA Group Operational Document CCA 204
- a certification agreement with the number 900038

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: November 10, 2000

C.M. Boschloo  
Certification Manager

© Integral publication of this certificate is allowed

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	surge-protection device
trade name	:	OBO
type	:	MC 50-B
class	:	I
maximum continuous operating voltage (Uc)	:	255 Vac
impuls current (10/350) (Iimp)	:	50 kA
voltage protection level (Up)	:	< 2,0 kV
extinguish capacity without fuses	:	> 12,5 kA effective
rated load current	:	125 A
short-circuit withstand	:	17,8 kA when protected with fuse-links. Fuse-links during test: manufacturer Ernst, 500 V, 500 A gL/gG, 120 kA
mounting method	:	flush-type, for mounting on top hat rail 35 mm (EN 50022)
degree of protection	:	IP 20
connection	:	10 mm <sup>2</sup> - 25 mm <sup>2</sup> flexible 10 mm <sup>2</sup> - 35 mm <sup>2</sup> stranded 10 mm <sup>2</sup> - 50 mm <sup>2</sup> solid
design	:	surge-protective device, voltage switching type, 1 port

**Additional information**

Markings: tradename, type designation and the complete electrical ratings are shown on the body

**TESTS****Test requirements**

IEC 61641-1:1998 C1:1998 + 37A/95/CDV


**Test result**

The test results are laid down in KEMA test file 2002756.01.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : H.L. Schendstok 

Checked by : L.J.W. van Megen 

**Factory-Locations**

OBO Bettermann GmbH & Co.,  
Huingser-Ring 52, MENDEN, Germany

**KEMA Registered Quality B.V.**

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands  
P.O. Box 9035, 6800 ET Arnhem, The Netherlands  
Telephone +31 26 3 56 28 50, Telefax +31 26 3 52 58 00